



MARCH 9, 2010
ADDENDUM NO. 1

ANNUAL SUPPLY OF
MISCELLANEOUS LUMINAIRES
BID NO. I006-2010

Bidders are directed to revise and incorporate into their bid the following changes in bid specifications:

Clarification for line items I006-2010-1-01 thru I006-2010-1-03:

Luminaires shall be high-pressure sodium, IES Type M-C-2 light distribution, with built-in multi tap ballast rated for operation at 240/480 volts, wired for 480 volts, conforming to TxDOT specification TRF 6030.001 revised 08-96, General Electric part number MSCL25S9M42FMC2072, NIGP 2856461827, or approved equivalent. Luminaires are to be installed into existing TxDOT continuous freeway lighting systems. Luminaires shall be packaged individually.

If you should have any other questions, do not hesitate to contact the Purchasing Office at 972-216-6201.

A handwritten signature in cursive script, appearing to read "Michele Brand", is written over a horizontal line.

Michele Brand

Manager of Purchasing and Telecommunications

ACCEPTANCE:

We, the undersigned, do hereby acknowledge receipt of this Addendum No. 1 to Bid No. I006-2010, Annual Supply of Miscellaneous Luminaires, and agree to the instructions herein written.

Company Name

Authorized Signature

Date